

**Fords Prairie Elementary School
 Centralia School District 401
 Centralia, WA**

Total Score = 54% or "Poor"

Date Scored: April 11, 2016

Scorer: Jerry Gee

	Program Space Needed?	Assigned Rating	Comment Areas						Comments
			Size	Adjacency	Storage	Fixed Equip.	Lighting, IAQ, Acoustics	Other	
Exterior									
Pedestrian Circulation	Y	Fair		X					A portion of the parent drop off area is in a dirt parking lot across the street. The pedestrian crossing does use a crossing guard.
Vehicle Circulation (incl. service vehicles)	Y	Poor	X	X					The parent drop off zone is either on the side of the street in front of the building or in a parking lot across the street from the main entrance. Buses load and unload in the parking lot behind the school.
Grounds and Fields	Y	Good							
Parking	Y	Poor	X	X					The school utilizes about three different parking areas. One is a paved parking lot behind the school, another is a dirt parking lot across the street from the school, and the third is a grassy area adjacent to the portable classrooms. The school does not have adequate parking. The school does not have any identified visitors parking.
Safety-Security, Signage, Fencing, Etc.	Y	Poor				X		X	The school does not have a camera/buzzer system at the main entrance. The school does have direct line of sight supervision of the front door. The doors between the buildings remain unlocked during the school day.

	Program Space Needed?	Assigned Rating	Comment Areas						Comments	
			Size	Adjacency	Storage	Fixed Equip.	Lighting, IAQ, Acoustics	Other		
Administration										
Administrators	Y	Good								
Reception-Clerical-Business	Y	Poor	x	x	x				x	The school does not have a reception area. The main office area is located in the foyer of the school. Noise, and privacy are a concern. The school does not have adequate built in storage for supplies and materials in the administrative area.
Discipline (Security, Detention, ISS, etc.)	N/A									
Administrative Support	Y	Poor	x		x	x				The faculty office work room is small in size. It is not equipped with restrooms. The school has one staff restroom.
Student Services										
Counselor, SW Offices	Y	Poor	x		x				x	The counselor is located in a small office area. The counselor does not have a reception area or conference room.
Clinic and Restroom	Y	Fair	x		x	x				The nurse area has one cot, the restroom is the staff restroom which is adjacent to the nursing area. The nursing area does not have adequate storage for supplies.
Student Services Support	Y	Good								

Program Space Needed?	Assigned Rating	Comment Areas						Comments
		Size	Adjacency	Storage	Fixed Equip.	Lighting, IAQ, Acoustics	Other	

Staff Support									
Staff Workrooms	Y	Poor	x		x	x			The school has a small workroom that is located by the main office area. The workroom houses the copier. Instructional materials and supplies are stored in the hallways throughout the building.
Staff Lounge	Y	Poor	x	x	x	x		x	The school has a table that will seat six people in the workroom. The area also has a coffee pot, microwave, sink and refrigerator. The school does not have a separate teachers lounge.
Staff Restrooms	Y	Unsatisfactory	x	x		x		x	There is one staff restroom which is located adjacent to the main office. It is also used by the school nurse for sick children.
Staff Support	Y	Good							

Food Services									
Food Preparation	Y	Fair	x						The kitchen is a warm and serve facility which is small in size.
Cafeteria	Y	Unsatisfactory	x		x		x		The cafeteria shares space with the PE program in the multipurpose room and reduces the school's ability to fully implement the PE program.
Dishwashing-Scullery	Y	Fair		x					The dishwashing area is not separated from the food preparation area.
Food Storage (Freezer, Cooler, Dry Storage)	Y	Fair	x		x	x			The school does not have adequate dry storage.
Food Services Support	Y	Poor	x	x		x		x	The kitchen area does not have an office area, restroom, or locker/changing area. The nearest custodial closet is located down the hall approximately 30 feet.

Program Space Needed?	Assigned Rating	Comment Areas						Comments
		Size	Adjacency	Storage	Fixed Equip.	Lighting, IAQ, Acoustics	Other	

Custodial-Maintenance								
Custodial/Maintenance	Y	Fair			x			The school does not have adequate storage for custodial supplies and equipment.
Restrooms and Corridors	Y	Poor				x	x	The school does not have an ADA accessible restroom. The restrooms are not well ventilated and are in need of renovation.
Custodial-Maintenance Support	Y	Good						

General Classrooms	Y	Fair			x	x		The general classrooms do not have adequate built in cabinetry for the storage of supplies and materials. Many of the classrooms do not have adequate outlets in the proper location. None of the classrooms have ceiling mounted projectors.
---------------------------	---	------	--	--	---	---	--	---

Early Childhood/Kindergarten								
Early Childhood Classrooms	Y	Fair	x		x	x		The early childhood classrooms are approximately 825 ft. ² in size. The sinks are not the appropriate height. The classrooms do not have adequate built in storage.
Early Childhood Support	Y	Poor		x		x		The early childhood classrooms do not have restrooms.

Program Space Needed?	Assigned Rating	Comment Areas						Comments
		Size	Adjacency	Storage	Fixed Equip.	Lighting, IAQ, Acoustics	Other	

Special Needs									
Special Education - Resource	Y	Fair			x				The resource rooms do not have adequate storage for supplies and materials.
Special Education - Cognitive	Y	Poor			x	x		x	Special education classrooms do not have restrooms or adequate storage for mobility devices and other equipment.
Special Education - Behavior	Y	Unsatisfactory	x	x	x	x	x	x	The behavioral disability classroom is located in a portable. It utilizes a safe room which does not have padding on the floor and has a door which can totally enclose the student.
Title I	Y	Fair			x				Title 1 room is a general classroom which does not have adequate built in storage for supplies and materials.
Speech Therapy	Y	Fair			x				Speech therapy is provided in a small room that does not have adequate storage.
Psychologist	N/A								
Special Needs Support	Y	Fair	x		x				The office areas are small for the number of staff and none of them have adequate storage for supplies and materials.

Physical Education									
Gymnasium/Multipurpose	Y	Poor	x		x			x	The physical education space is extremely small at 2125 ft. ² . There is not adequate storage for physical education equipment.
Physical Education Support	Y	Poor	x		x				The physical education teacher does not have a separate office.

	Program Space Needed?	Assigned Rating	Comment Areas							Comments
			Size	Adjacency	Storage	Fixed Equip.	Lighting, IAQ, Acoustics	Other		
Music										
Music	Y	Unsatisfactory	x	x	x	x	x	x	x	Music instruction occurs in a portable.
Music Support	Y	Unsatisfactory	x	x	x	x	x	x	x	Music is located in a portable.
Library - Media										
Library	Y	Poor	x		x				x	The library is approximately 900 ft. ² . It is not large enough to accommodate the needs of the school. It does not have adequate storage for audiovisual equipment, books, and other library equipment.
Library Support	Y	Poor	x		x				x	The library does not have a workroom or adequate storage.
Computer Labs										
Computer Lab(s)	Y	Unsatisfactory	x	x	x	x	x	x	x	Computer lab is housed in a portable area
Computer Lab Support	Y	Unsatisfactory	x	x	x	x	x	x	x	The computer lab is housed in a portable.
Visual Arts										
Art	Y	Unsatisfactory	x	x	x	x	x	x	x	The school does not have an art classroom. Art is taught in the general classrooms by each individual teacher.
Art Support	Y	Unsatisfactory	x	x	x	x	x	x	x	The school does not have an art classroom.

	Program Space Needed?	Assigned Rating	Comment Areas						Comments
			Size	Adjacency	Storage	Fixed Equip.	Lighting, IAQ, Acoustics	Other	
Science									
Science Room	N								
Science Room Support	N								
Performance									
Stage	Y	Unsatisfactory	x	x	x	x	x	x	The school does not have a stage.
Auditorium	Y	Poor	x						The multipurpose room is not adequate in size for all of the parents who want to attend school programs.
Stage-Auditorium Support	Y	Unsatisfactory	x	x	x	x	x	x	The school does not have a stage or any other auditorium support facilities
Gifted Education									
	N								